

DEW POINT MONITORING


UNDERSTANDING, PLANNING and CONFIGURING – and thus avoiding condensation

The dew point temperature is that temperature at which condensation develops on a surface.

For example: At an air temperature of 24.0°C and at 60% relative humidity, the dew point is at a temperature of 15.8°C. If there is a surface in this room that is 15.8°C or colder, water droplets will develop on it.

The objective of dew point monitoring is to avoid this. In buildings, condensation, sometimes also referred to as „dew water“, occurs particularly on cooled pipes and surfaces of air conditioning systems. The moisture of the warm room air can settle here if surface and dew point temperatures approach similar values.

Thanks to the monitoring process, the building automation system can implement timely measures in order to avoid droplet formation. For example, the temperature of the coolant may be raised (reduction of air conditioning), the room temperature may be raised, or the air humidity lowered (ventilation).



DEW POINT MONITORING

SETTING UP – Example of Cala KNX room controller

SETTING THE PARAMETERS IN THE ETS

Cooling medium temperature monitoring of the Cala KNX

Dew point monitoring can be set up with **Cala KNX TH** or **Cala AQS/TH**. Both measure the room temperature and air humidity and may control heating and cooling systems. **Cooling medium temperature monitoring** is used for the dew point function.

In the ETS application of the Cala KNX, *Monitoring of the cooling medium temperature* is activated in the menu *Dew point measurement*. Then, the menu within the *Cooling medium temperature monitoring* allows you to set the offset, switch delays and blocks. The offset serves to determine the temperature in degrees for triggering a dew point warning via the switch output before reaching the critical dew point temperature. The offset allows giving the system some reaction time for counter-measures. The following applies: threshold value for switching output cooling medium temperature = dew point + offset.

Sensor T-NTC at the input/interface of Cala KNX

If the current cooling medium temperature is to be provided by the **sensor T-NTC**, the sensor is connected to one input (interface) of Cala KNX and the **interface** is set up in the ETS application of Cala KNX.

The input/interface is activated in the ETS application at the menu *Push button interfaces*. Then, the function *Temperature sensor NTC* is selected in the *Interface X* menu.

KNX K4 actuator

The air conditioning actuator KNX K4 is used to control the valves in the heating and cooling system. In order to take over temperature control from Cala KNX, select the *Control type: via temperature controller*.

1.1.2 Cala KNX TH > Cooling medium temp. monitoring	
General settings	Threshold value: -----
Screen	Maintain the offset received via communication object
Button tone	not
Menus	
Temperature measured value	Threshold value = dew point + offset
Temperature threshold values	Start offset in 0.1°C valid until 1.communication 30
Temperature PI control	Step size for offset change 0.1°C
Summer compensation	Hysteresis setting <input type="radio"/> in % <input checked="" type="radio"/> absolute
Humidity measured value	Hysteresis of the threshold value in 0.1°C 50
Humidity threshold values	Threshold value sends not
Dew point measurement	
Cooling medium temp. monitoring	
Absolute humidity	Switching output: -----
Comfort field	Output is at (TV = threshold value) TV below = 1 TV + Hyst. above = 0
Humidity PI control	Delays can be set via objects (in seconds) <input checked="" type="radio"/> No <input type="radio"/> Yes
Variable comparator	Delay from 0 to 1 none
Computer	Delay from 1 to 0 none
Logic	Switching output sends on change
Push button interfaces	Block: -----
Interface 1	Use block of the switching output <input checked="" type="radio"/> No <input type="radio"/> Yes

1.1.2 Cala KNX TH > Interface 1	
Absolute humidity	Function Temperature sensor (NTC)
Comfort field	Use malfunction object <input checked="" type="radio"/> No <input type="radio"/> Yes
Humidity PI control	Offset in 0.1°C 0
Variable comparator	Use external measured value <input checked="" type="radio"/> No <input type="radio"/> Yes
Computer	
Logic	
Push button interfaces	Transmission behaviour on change
Interface 1	From change of 0.5°C

LINKING THE COMMUNICATION OBJECTS

An overview of the most important object links for dew point monitoring:

