


Cala KNX M-T CH Push Button with Temperature Sensor



Cala KNX M1-T CH Item numbers 70861 (white), 70863 (black)



Cala KNX M2-T CH Item numbers 70871 (white), 70873 (black)



Cala KNX M4-T CH Item numbers 70881 (white), 70883 (black)



Installation and Adjustment

1.	Description	3
	1.0.1. Area function	
1.1.	Scope of delivery	4
1.2.	Technical data	5
	1.2.1. Accuracy of the measurement	5
2.	Installation and commissioning	5
2.1.	Installation location	
2.2.	Device structure	7
	2.2.1. Casing	7
2.3.	Installation of the sensor	7
3.	Commissioning	8
3.1.	Addressing of the device at the bus	8
4.	Maintenance	8
5.	Disposal	9
<u> </u>		
6.		
6.	Transfer protocol 1 List of all communications objects 1	10
6.	Transfer protocol 1	10 10
6. 6.1. 7.	Transfer protocol 1 List of all communications objects 1	10 10 13
6.1. 7.1. 7.2.	Transfer protocol 1 List of all communications objects 1 Setting the parameters 1 Behaviour on power failure/ restoration of power 1 General settings 1	10 10 13 13 13
6.1. 7.1. 7.2.	Transfer protocol 1 List of all communications objects 1 Setting the parameters 1 Behaviour on power failure/ restoration of power 1	10 10 13 13 13
6.1. 7.1. 7.2. 7.3.	Transfer protocol 1 List of all communications objects 1 Setting the parameters 1 Behaviour on power failure/ restoration of power 1 General settings 1 Temperature measured value 1 Push button 1	10 10 13 13 13 13 13 14
6.1. 7.1. 7.2. 7.3.	Transfer protocol 1 List of all communications objects 1 Setting the parameters 1 Behaviour on power failure/ restoration of power 1 General settings 1 Temperature measured value 1	10 10 13 13 13 13 13 14
6.1. 7.1. 7.2. 7.3.	Transfer protocol 1 List of all communications objects 1 Setting the parameters 1 Behaviour on power failure/ restoration of power 1 General settings 1 Temperature measured value 1 Push button 1	10 10 13 13 13 13 14 15
6.1. 7.1. 7.2. 7.3. 7.4. 7.5.	Transfer protocol 1 List of all communications objects 1 Setting the parameters 1 Behaviour on power failure/ restoration of power 1 General settings 1 Temperature measured value 1 Push button 1 7.4.1. Push button 1 / 2 / 3 / 4 1 7.4.2. Control modes for drive control 1 LEDs 1	10 10 13 13 13 13 14 15 18 19
6.1. 7.1. 7.2. 7.3. 7.4. 7.5.	Transfer protocol 1 List of all communications objects 1 Setting the parameters 1 Behaviour on power failure/ restoration of power 1 General settings 1 Temperature measured value 1 Push button 1 7.4.1. Push button 1 / 2 / 3 / 4 1 7.4.2. Control modes for drive control 1 LEDs 1 Logic 1	10 10 13 13 13 13 14 15 18 19 20
6.1. 7.1. 7.2. 7.3. 7.4. 7.5.	Transfer protocol 1 List of all communications objects 1 Setting the parameters 1 Behaviour on power failure/ restoration of power 1 General settings 1 Temperature measured value 1 Push button 1 7.4.1. Push button 1 / 2 / 3 / 4 1 7.4.2. Control modes for drive control 1 LEDs 1	10 10 13 13 13 13 14 15 18 19 20 21

This manual is amended periodically and will be brought into line with new software releases. The change status (software version and date) can be found in the contents footer. If you have a device with a later software version, please check

www.elsner-elektronik.de in the menu area "Service" to find out whether a more up-todate version of the manual is available.

Clarification of signs used in this manual

\wedge	Safety advice.
	Safety advice for working on electrical connections, components, etc.
DANGER!	indicates an immediately hazardous situation which will lead to death or severe injuries if it is not avoided.
WARNING!	indicates a potentially hazardous situation which may lead to death or severe injuries if it is not avoided.
CAUTION!	indicates a potentially hazardous situation which may lead to trivial or minor injuries if it is not avoided.
	! indicates a situation which may lead to damage to property if it is not avoided.
ETS	In the ETS tables, the parameter default settings are marked by <u>underlining</u> .

1. Description

The **Cala KNX M-T CH push button** has touch-sensitive buttons, with which functions in the KNX building bus system can be called, such as switch lights and devices, dim, activate drives, send values, scenarios. A white LED is integrated into each touch button, the behaviour of which can be adjusted.

A temperature sensor is integrated into **Cala KNX M-T CH**. An external temperature reading can be received via the bus and processed with its own data to create a total temperature (mixed value).

Communication objects can be connected by AND and OR logic gates.

The device is supplemented with a frame of the switch series used in the building, and thus fits seamlessly into the interior fittings.

Cala KNX M1-T CH functions:

 1 Touch bus button, can be configured as switch, selector switch, dimmer, blind (position and slats up/stop OR down/stop), shutters (up/down/stop), awning (in/out/stop), window (closed/open/stop), as 8 or 16-bit encoder or for scenario recall/storage

Cala KNX M2-T CH functions:

- **2 Touch bus button**, can be configured as switch, selector switch, dimmer, for operating drives, as 8 or 16-bit encoder or for scenario recall/storage
- Area function when touching both push buttons. Can be configured as switch, selector switch, as 8 or 16 bit encoder or for scenario recall

Cala KNX M4-T CH functions:

- **4 Touch bus button**, can be configured as switch, selector switch, dimmer, for operating drives, as 8 or 16-bit encoder or for scenario recall/storage
- Area function when touching two or more push buttons. Can be configured as switch, selector switch, as 8 or 16 bit encoder or for scenario recall

Function of all models:

- One LED per touch area. On for object value = 1 / Off for object value = 0, On after pressing button for settable time or always off. Settable, as to whether LED flashes at block object value = 1
- **Temperature** measurements. **Mixed value** from own measured value and external values (proportion can be set by percentage)
- 2 AND and 2 OR logic gates each with 4 inputs. All switching events as well as 8 logic inputs (in the form of communications objects) can be used as inputs for the logic gates. The output from each gate can be configured optionally as 1-bit or 2 x 8-bit

Configuration is made using the KNX software as of ETS 5. The **product file** can be downloaded from the ETS online catalogue and the Elsner Elektronik website on **www.elsner-elektronik.de** in the "Service" menu. There you will also find the product manual.

1.0.1. Area function


If the area function in ETS has been activated, another function is available alongside the regular key functions. This is triggered by touching multiple keys, e.g. if you touch the sensor with the palm of your hand.

Using the area function

If a key is pressed and another (different) key is touched within 0.2 seconds, the action set in the ETS is performed for the area operation (See Fig. 1 a) and b)). The keys are then blocked for 0.5 seconds.

Using the normal key function

If a key is pressed and no other key is touched within 0.2 seconds, the normal key function is enabled/provided for 5 seconds (See Fig. 1 c) and d)). This is extended for 5 seconds with each push of the button.



If the area function in the ETS is disabled, the keys can be used normally at any time.

1.1. Scope of delivery

• Push button in casing

Mounting adapter with screws

Additionally required (not included in the deliverables):

- Cover frame (for insert 60 x 60 mm) and mounting plate (77 mm) for swiss installation standard
- Inlet box

1.2. Technical data

Casing	Genuine glass, plastic
Colours	 similar to RAL 9010 pure white similar to RAL 9005 deep black
Installation	Installation in inlet box
Degree of protection	IP 20
Dimensions	Housing approx. 60 x 60 (W x H, mm), Installation depth approx. 10 mm
Total weight	approx. 50 g
Ambient temperature	Operating -25+80°C, storage -30+85°C
Ambient humidity	max. 95% RH, avoid condensation
Operating voltage	KNX bus voltage
Bus current	max. 15 mA
Data output	KNX +/- Bus plug-in terminal
Group addresses	max. 183
Allocations	max. 183
Communication objects	Cala KNX M1-T CH: 44 Cala KNX M2-T CH: 55 Cala KNX M4-T CH: 73
Temperature measurement range	-25+80°C

The product is compliant with the provisions of EU Directives.

1.2.1. Accuracy of the measurement

Measurement variations from permanent sources of interference (see chapter *Installation position*) can be corrected in the ETS in order to ensure the specified accuracy of the sensor (offset).

When **measuring temperature**, the self-heating of the device is considered by the electronics. The heating is compensated for in the device.

2. Installation and commissioning



Installation, testing, operational start-up and troubleshooting should only be performed by an authorised electrician.

CAUTION! Live voltage!

There are unprotected live components inside the device.

• Inspect the device for damage before installation. Only put undamaged devices into operation.

• Comply with the locally applicable directives, regulations and provisions for electrical installation.

• Immediately take the device or system out of service and secure it against unintentional switch-on if risk-free operation is no longer guaranteed.

Use the device exclusively for building automation and observe the operating instructions. Improper use, modifications to the device or failure to observe the operating instructions will invalidate any warranty or guarantee claims.

Operate the device only as a fixed-site installation, i.e. only in assembled condition and after conclusion of all installation and operational start-up tasks, and only in the surroundings designated for it.

Elsner Elektronik is not liable for any changes in norms and standards which may occur after publication of these operating instructions.

2.1. Installation location

The **Cala KNX M-T CH push button** is made for wall mounting in an inlet box. The device is supplemented with a frame of the 60 mm swiss installation standard.



May be installed and operated in dry interior rooms only.

When selecting an installation location, ensure that the measurement results are affected as little as possible by external influences. Possible sources of interference include:

- Direct sunlight
- Drafts from windows and doors
- Draft from ducts which lead from other rooms or from the outside to the junction box in which the sensor is mounted
- Warming or cooling of the building structure on which the sensor is mounted, e.g. due to sunlight, heating or cold water pipes
- Connection lines and ducts which lead from warmer or colder areas to the sensor

Measurement variations from permanent sources of interference can be corrected in the ETS in order to ensure the specified accuracy of the sensor (offset).

2.2. Device structure

2.2.1. Casing




Fig. 2: Front

- 1 Ventilation slit (top and bottom)
- 2 Touch areas with LEDs





Fig. 3: Rear

- 1 Mounting adapter
- 2 KNX terminal BUS +/-
- 3 Catches
- 4 Programming LED (recessed)
- 5 Programming LED (recessed) for teaching the device

2.3. Installation of the sensor

First of all fit the windproof inlet box with connection. Also seal inlet pipes to avoid infiltration.



Turn the screws little way into the mounting adapter.

. Fig. 4

Hook the mounting adapter into the mounting plate of the switch system and tighten the screws.



Screw the mounting plate onto the inlet box

Position the frame of the switching programme. Connect the bus line +/- to the black-red plug.

Pin the housing with the notches on to the mounting adapter, so that device and frame are fixed. The device has to be inserted such that the bus terminal faces up (see Fig. 3). This is necessary for a correct temperature measurement and for Cala KNX M2-T CH and Cala KNX M4-T CH also for button allocation.

3. Commissioning

Never expose the device to water (e.g. rain) or dust. This can damage the electronics. You must not exceed a relative humidity of 95%. Avoid condensation.

After the bus voltage has been applied, the device will enter an initialisation phase lasting a few seconds. During this phase no information can be received or sent via the bus.

3.1. Addressing of the device at the bus

The individual address is assigned via the ETS. A button and a control LED are located on the unit for this purpose (Fig. 3, No. 4+5).

The equipment is delivered with the bus address 15.15.255. Another address can be programmed using the ETS.

When programming mode is active, the programming LED lights up and all other LEDs also flash.

4. Maintenance

Ventilation slits must not be dirty of covered. As a rule, it is sufficient to wipe the device with a soft, dry cloth as required.

5. Disposal

After use, the device must be disposed of in accordance with the legal regulations. Do not dispose of it with the household waste!

6. Transfer protocol

Units:

Temperatures in degrees Celsius

6.1. List of all communications objects

Abbreviation flags:

- C Communication
- R Read
- W Write
- T Transmit
- U Update

No	Text	Function	Flags	DPT type	Size
0	Software version	Output	R-CT	[217.1] DPT_Version	2 Bytes
Only	with Cala KNX M2-T CH and Cal	a KNX M4-T	СН		
31	Area operation on/off	Input	-WC-	[1.1] DPT_Switch	1 Bit
32	Area operation Output: Switch	Output	R-CT	depending on setting	2 Bytes
For a	all models				
33	All LEDs On/Off	Input	-WC-	[1.1] DPT_Switch	1 Bit
34	All LEDs Brightness	Input	-WC-	[5.1] DPT_Scaling	1 Byte
35	LED 1 on/off	Input	-WC-	[1.1] DPT_Switch	1 Bit
36	LED 1 Block	Input	-WC-	[1.1] DPT_Switch	1 Bit
Only	with Cala KNX M2-T CH and Cal	a KNX M4-T	СН		
37	LED 2 on/off	Input	-WC-	[1.1] DPT_Switch	1 Bit
38	LED 2 Block	Input	-WC-	[1.1] DPT_Switch	1 Bit
Only	with Cala KNX M4-T CH				
39	LED 3 on/off	Input	-WC-	[1.1] DPT_Switch	1 Bit
40	LED 3 Block	Input	-WC-	[1.1] DPT_Switch	1 Bit
41	LED 4 on/off	Input	-WC-	[1.1] DPT_Switch	1 Bit
42	LED 4 Block	Input	-WC-	[1.1] DPT_Switch	1 Bit
For a	all models				
51	Temperature sensor: malfunc- tion	Output	R-CT	[1.1] DPT_Switch	1 Bit
52	Temperature sensor: meas- ured value external	Input	-WCT	[9.1] DPT_Value_Temp	2 Bytes
53	Temperature sensor: meas- ured value	Output	R-CT	[9.1] DPT_Value_Temp	2 Bytes
54	Temperature sensor: meas- ured value total	Output	R-CT	[9.1] DPT_Value_Temp	2 Bytes
55	Temperature sensor: meas- ured value min./max. query	Input	-WC-	[1.17] DPT_Trigger	1 Bit

No	Text	Function	Flags	DPT type	Size
56	Temperature sensor: meas- ured value minimum	Output	R-CT	[9.1] DPT_Value_Temp	2 Bytes
57	Temperature sensor: meas- ured value maximum	Output	R-CT	[9.1] DPT_Value_Temp	2 Bytes
58	Temperature sensor: meas- ured value min./max. reset	Input	-WC-	[1.17] DPT_Trigger	1 Bit
61	Push button 1 long-term	Output	R-CT	[1.8] DPT_UpDown	1 Bit
62	Push button 1 short-term	Output	R-CT	[1.10] DPT_Start	1 Bit
63	Push button 1 switching	Output	R-CT	[1.1] DPT_Switch	1 Bit
64	Push button 1 dimming	Input / Output	RWCT	[3.7] DPT_Con- trol_Dimming	4 Bit
65	Push button 1 encoder 8 bit	Output	R-CT	[5.10] DPT_Value_1_U- count	1 Byte
66	Push button 1 encoder 16 bit	Output	R-CT	[9] 9.xxx	2 Bytes
67	Push button 1 Scene	Output	R-CT	[18.1] DPT_SceneCon- trol	1 Byte
Only	with Cala KNX M2-T CH and Cal	a KNX M4-1	СН		
68	Push button 2 long-term	Output	R-CT	[1.8] DPT_UpDown	1 Bit
69	Push button 2 short-term	Output	R-CT	[1.10] DPT_Start	1 Bit
70	Push button 2 switching	Output	R-CT	[1.1] DPT_Switch	1 Bit
71	Push button 2 dimming	Input / Output	RWCT	[3.7] DPT_Con- trol_Dimming	4 Bit
72	Push button 2 encoder 8 bit	Output	R-CT	[5.10] DPT_Value_1_U- count	1 Byte
73	Push button 2 encoder 16 bit	Output	R-CT	[9] 9.xxx	2 Bytes
74	Push button 2 Scene	Output	R-CT	[18.1] DPT_SceneCon- trol	1 Byte
Only	with Cala KNX M4-T CH				
75	Push button 3 long-term	Output	R-CT	[1.8] DPT_UpDown	1 Bit
76	Push button 3 short-term	Output	R-CT	[1.10] DPT_Start	1 Bit
77	Push-button 3 switching	Output	R-CT	[1.1] DPT_Switch	1 Bit
78	Push button 3 dimming	Input / Output	RWCT	[3.7] DPT_Con- trol_Dimming	4 Bit
79	Push-button 3 encoder 8 bit	Output	R-CT	[5.10] DPT_Value_1_U- count	1 Byte
80	Push-button 3 encoder 16 bit	Output	R-CT	[9] 9.xxx	2 Bytes
81	Push button 3 Scene	Output	R-CT	[18.1] DPT_SceneCon- trol	1 Byte
82	Push button 4 long-term	Output	R-CT	[1.8] DPT_UpDown	1 Bit
83	Push button 4 short-term	Output	R-CT	[1.10] DPT_Start	1 Bit
84	Push-button 4 switching	Output	R-CT	[1.1] DPT_Switch	1 Bit
85	Push button 4 dimming	Input / Output	RWCT	[3.7] DPT_Con- trol_Dimming	4 Bit

No	Text	Function	Flags	DPT type	Size
86	Push-button 4 encoder 8 bit	Output	R-CT	[5.10] DPT_Value_1_U- count	1 Byte
87	Push-button 4 encoder 16 bit	Output	R-CT	[9] 9.xxx	2 Bytes
88	Push button 4 Scene	Output	R-CT	[18.1] DPT_SceneCon- trol	1 Byte
For a	all models				
91	Logic input 1	Input	-WC-	[1.2] DPT_Bool	1 Bit
92	Logic input 2	Input	-WC-	[1.2] DPT_Bool	1 Bit
93	Logic input 3	Input	-WC-	[1.2] DPT_Bool	1 Bit
94	Logic input 4	Input	-WC-	[1.2] DPT_Bool	1 Bit
95	Logic input 5	Input	-WC-	[1.2] DPT_Bool	1 Bit
96	Logic input 6	Input	-WC-	[1.2] DPT_Bool	1 Bit
97	Logic input 7	Input	-WC-	[1.2] DPT_Bool	1 Bit
98	Logic input 8	Input	-WC-	[1.2] DPT_Bool	1 Bit
101	AND logic 1: 1 bit switching output	Output	R-CT	[1.2] DPT_Bool	1 Bit
102	AND logic 1: 8 bit output A	Output	R-CT	[5.010] DPT Value_1_Ucount	1 Byte
103	AND logic 1: 8 bit output B	Output	R-CT	[5.010] DPT Value_1_Ucount	1 Byte
104	AND logic 1: Block	Input	-WC-	[1.1] DPT_Switch	1 Bit
105	AND logic 2: 1 bit switching output	Output	R-CT	[1.2] DPT_Bool	1 Bit
106	AND logic 2: 8 bit output A	Output	R-CT	[5.010] DPT Value_1_Ucount	1 Byte
107	AND logic 2: 8 bit output B	Output	R-CT	[5.010] DPT Value_1_Ucount	1 Byte
108	AND logic 2: Block	Input	-WC-	[1.1] DPT_Switch	1 Bit
109	OR logic 1: 1 bit switching out- put	Output	R-CT	[1.2] DPT_Bool	1 Bit
110	OR logic 1: 8 bit output A	Output	R-CT	[5.010] DPT Value_1_Ucount	1 Byte
111	OR logic 1: 8 bit output B	Output	R-CT	[5.010] DPT Value_1_Ucount	1 Byte
112	OR logic 1: Block	Input	-WC-	[1.1] DPT_Switch	1 Bit
113	OR logic 2: 1 bit switching out- put	Output	R-CT	[1.2] DPT_Bool	1 Bit
114	OR logic 2: 8 bit output A	Output	R-CT	[5.010] DPT Value_1_Ucount	1 Byte
115	OR logic 2: 8 bit output B	Output	R-CT	[5.010] DPT Value_1_Ucount	1 Byte
116	OR logic 2: Block	Input	-WC-	[1.1] DPT_Switch	1 Bit

7. Setting the parameters

7.1. Behaviour on power failure/ restoration of power

Behaviour following a failure of the bus power supply:

The device sends nothing.

Behaviour on bus restoration of power and following programming or reset:

The device sends all outputs according to their send behaviour set in the parameters with the delays established in the "General settings" parameter block.

7.2. General settings

Set the basic properties of the data transmission.

Transmission delay after reset/bus restora- tion	<u>5 s</u> • • 300 s
Maximum message rate	 1 message per second 10 messages per second 50 messages per second

7.3. Temperature measured value

Select, whether a malfunction object is to be sent if the sensor is faulty.

Use malfunction object	No • Yes

Use **Offsets** to adjust the readings to be sent.

Offset in 0.1°C	-5050; 0

The unit can calculate a **mixed value** from its own reading and an external value. Set the mixed value calculation if desired. If an external portion is used, all of the following settings (threshold values, etc.) are related to the overall reading.

Use external measured value	<u>No</u> •Yes
Ext. Reading proportion of the total reading	5% • 10% • • <u>50%</u> • • 100%
Sending pattern for internal and total measured value	 <u>never</u> periodically on change on change and periodically

At and above change of (<i>if sent on change</i>)	0.1°C • 0.2°C • <u>0.5°C</u> • • 5.0°C
Send cycle (if sent periodically)	5 s • <u>10 s</u> • • 2 h

The **minimum and maximum readings** can be saved and sent to the bus. Use the "Reset temperature min/max. value" objects to reset the values to the current readings. The values are not retained after a reset.

Use minimum and maximum value	<u>No</u> • Yes

7.4. Push button

On Cala KNX M2-T CH and Cala KNX M4-T CH there is a screen control with an additional function. It is activated by simultaneously touching multiple push buttons. The value of the activation object and the function is set for the screen control.

Set whether you want to use the screen control.

Use screen control	No • Yes
Use screen control	Yes
Activation object assessment	• Value 1 = active Value 0 = inactive
	• Value 0 = active Value 1 = inactive
Object value after reset	0 • <u>1</u>
Function	• <u>Switch</u>
	Selector switch
	• 8 bit value 0 255
	• 8 bit value 0 100%
	 16-bit floating point value
	Scenario recall
Value (<i>switch</i>)	0 • <u>1</u>
Value (8 bit value 0 255)	0 • • <u>255</u>
Value (8 bit value 0 100%)	0 • • <u>100</u>
Value in 0.1 (16 bit value floating point)	-6707600 • • 6707600; <u>10</u>
Scenario number (Scenario recall)	<u>1</u> ••64

Enable the push button The menus for the other settings of the push buttons are shown on them.

Use push button 1 (top left)	<u>No</u> •Yes
Use push button 2 (top right)	<u>No</u> •Yes
Use push button 3 (bottom left)	<u>No</u> •Yes
Use push button 4 (bottom right)	<u>No</u> •Yes

14

7.4.1. Push button 1 / 2 / 3 / 4

Set the function of the push button.

Function	 <u>Switch</u> Selector switch Blind Shutters Awning Windows Dimmer 8-bit encoder 16-bit encoder Scenario recall/ Scenario storage
----------	--

Push button as switch

Specify which value is sent when pressing/holding the push button and when.

Function	Switch
Command when pressing the button	O Send
	• 1 Send
	 Do not send message
Command when releasing the button	O Send
	• 1 Send
	 Do not send message
Send value	 If there is a change
	• on change to 1
	• on change to 0
	 on change and periodically
	 on change to 1 and periodically
	 on change to 0 and periodically
Cycle (if transmission is "cyclical")	5 s • • <u>1 min •</u> • 2 h

Push button as selector switch

Specify whether a switch is performed when pressing or holding and whether there is an additional function after holding the push button for a long period.

Function	Selector switch
Use additional function for button held down	<u>No</u> •Yes
Use additional function for button held down	No
Command when pressing the button	Switch Do not send message
Command when releasing the button	Switch Do not send message

Use additional function for button held down	Yes
Time between tap and hold (0.1 sec)	0 50; <u>10</u>
Command when pressing the button	Do not send message
Command when releasing before time expires	Switch Do not send message
Command when pressing the button	 0 Send 1 Send Switch Do not send message
Command when releasing the button	 0 Send 1 Send Switch Do not send message
Send value	 If there is a change on change to 1 on change to 0 on change and periodically on change to 1 and periodically on change to 0 and periodically
Transmission cycle (if cyclically sent)	5 s • <u>10 s</u> • • 2 h

Push button as blind, shutter, awning or window control

Specify the push button function and the control mode.

Function	Blind / shutters / aw	ning / window
Command (button function)	Up • Down Up • Down • Up/Down Retract • Extend • Retract/Extend Open • Close • Open/ Close	(Blind) (Shutters) (Awning) (Window)
Control mode*	• <u>Standard</u> • Standard inverted • Comfort mode • Dead man switch	

* For additional setting details, see 💷 "Control modes for drive control" on page 18

Push button as dimmer

If the push button should be used as a dimmer, select the function "Dimmer" and define the push button function, time interval (switching/dimming) and if required, the repeat interval for extended pressing of the push button.

Function	Dimmer

Command	• <u>Brighter</u> • Darker • Lighter/Darker
Time between switching and dimming (in 0.1 s)	0 50; <u>5</u>
Repeat the dim command	No • Yes
Repeat the dim command with a long hold of the button	every 0.1 s • • <u>every 0.5 s</u> • • every 2 s
Dim by	100% • • <u>6%</u> • • 1.5%

Push button as 8 bit encoder

If the push button is to be used as an 8-bit encoder, select the function "8-bit encoder" and define which value is to be transmitted.

Range	• <u>0</u> <u>255</u> • <u>0%</u> <u>100%</u> • <u>0°</u> <u>360°</u>
Value	• <u>0</u> 255 • <u>0</u> 100 • <u>0</u> ° 360°

Push button as 16 bit encoder

If the push button is to be used as a 16-bit encoder, select the function "16-bit encoder" and define which value is to be transmitted.

Value (in 0.1)	-6707600 6707600; <u>0</u>
----------------	----------------------------

Push button as scenario control

If a scenario is to be recalled and saved with a push button, select the "Recall scenario / Save scenario" function and specify whether the push button should also be used to save the scenario (press longer)

Scenario (0-63, corresponds to scenario no. 1-64)	<u>0</u> 63
Scenario function	Call up • Call up and storage
Press button longer than (in 0.1s) > Scenario memory (for call up and storage)	0 <u>50</u>

7.4.2. Control modes for drive control

	short:	hold
Blind	Stop/Step	Up or down
Shutters	Stop	Up or down
Awning	Stop	In or out
Windows	Stop	Closed or open

Behaviour on button actuation in standard control mode:

Standard:

If briefly operated, the drive will move incrementally or stops. If operated longer, the drive will move up to the end position. The time difference between "short" and "long" is set individually.

Control mode	Standard
Behavior during button operation: short = stop/increment long = Up or Down	
Time between short and long in 0.1 seconds	150; <u>10</u>

Standard inverted:

When pushed shortly, the drive moves up to the end position. When pushed for longer, the drive moves incrementally or stops. The time difference between "short" and "long" and the repeat interval is set individually.

Control mode	Standard inverted
Behavior during button operation: short = Up or Down long = Stop/Step	
Time between short and long in 0.1 seconds	150; <u>10</u>
Repeat the step command for a long button press	every 0.1 s • every 2 sec; every 0.5 sec

Comfort mode:

In the **comfort mode** actuating the button briefly, a bit longer and long will trigger different responses of the drive. The time intervals are set individually.

Short actuation (shorter than Time 1): The drive is positioned step-wise and stopped. **Holding it slightly longer** (longer than Time 1, but shorter than Time 1+2): Drive running. Drive stops when the button is released.

Long holding (release after Time 1+2 runs out): Drive moves independently to the end position. The movement can be interrupted by a short tap.

Fig. 6 Time interval comfort mode diagram

Time 1 Time 2	
0 1	1 + 2
Point in time 0:	Actuate of button, start of time 1
Release before time 1 expired:	step (or stop if drive is moving)
Point in time 1:	End of time 1, start of time 2 Moving command
Release after time 1 expired	
but before time 2 expires:	Stop
Release after time 1 + 2 expired:	Move into end position
Control mode	Comfort mode
Behavior during button operation: Button is pushed and released before time 1 expired = stop/step held longer than time 1 = Up or Down released between time 1 and 1-2= stop released after time 1 +2 = no more stop	
Time 1	0.0s • 2 s; <u>0.4 s</u>
Time 2	0 s • 2 s; <u>2 s</u>

Dead man's switch:

The drive moves as soon as the button is actuated and stops as soon as the button is released.

Control mode	Dead man's switch
Behavior during button operation: Push button = Up or Down command Release button = Stop command	

7.5. LEDs

Set the LED mode.

LED mode	All LEDs off
	 All LEDs as ambient lighting
	 All LEDs individually controllable

All LEDs as ambient lighting

If all LEDs are to be used as ambient lighting, illuminate all simultaneously. Set the brightness of the LEDs, whether objects are used and whether the LEDs switch off automatically after pushing the button.

LED mode	All LEDs as ambient lighting
Brightness	0 100%; <u>30%</u>

Use objects	<u>No</u> •Yes
Object value on/off after reset (<i>if objects are used</i>)	0 • <u>1</u>
Use automatic switch-off after pressing a button	No • <u>Yes</u>
Switch off after (is automatic switch off is used)	1 255; <u>30 secs. after pressing</u>

All LEDs individually controllable

This is where you set the brightness of the LEDs, whether objects are used and whether the LEDs switch off automatically after pushing the button.

LED mode	All LEDs individually controllable
Brightness	0 100%; <u>30%</u>
Use objects	<u>No</u> •Yes
Object value on/off after reset (<i>if objects are used</i>)	0 • <u>1</u>
Function LED 1 (top left) / 2 (top right) / 3 (bottom left) / 4 (bottom right)	 always OFF <u>On after pressing button for settable time</u> On for object value = 1 / Off for object value = 0
Lighting period after pressing (<i>if "On after pressing button for a settable time"</i>)	1 5 seconds ; <u>3 seconds</u>
Object value after reset (<i>if</i> "On for object value = 1 / Off for object value = 0)	0 • <u>1</u>
Use block object (<i>if "On for object value = 1</i> / <i>Off for object value = 0</i>)	<u>No</u> •Yes

7.6. Logic

The device has 8 logic inputs, 2 AND and 2 OR logic gates.

Activate the logic inputs and assign object values up to 1st communication.

Use logic inputs	Yes • <u>No</u>
Object value prior to 1st communication for	
- Logic input 1 8	<u>0</u> •1

Activate the required logic outputs

AND logic

AND logic 1/2	not active • active
---------------	---------------------

OR logic

OR logic 1/2	not active • active
--------------	---------------------

7.6.1. AND logic 1+2 and OR logic outputs 1+2

The same setting options are available for AND and OR logic.

Each logic output may transmit one 1-bit or two 8-bit objects. Determine what the out put should send if logic = 1 and = 0.

1. / 2. / 3. / 4. Input	 <u>Do not use</u> Logic inputs 18 Logic inputs 18 inverted Temperature sensor malfunction ON Temperature sensor malfunction OFF
Output type	• <u>a 1-bit-object</u> • sends two 8-bit objects

If the output type is a 1-bit object, set the output values for the various conditions.

Output value if logic = 1	<u>1</u> •0
Output value if logic = 0	1 • <u>0</u>
Output value If block active	1 • <u>0</u>
Output value if monitoring time exceeded	1 • <u>0</u>

If the **output type is two 8-bit objects**, set the type of object and the output values for the various conditions.

Object type	• value (0255) • Percent (0100%) • Angle (0360°) • Scene call-up (063)
Output value object A if logic = 1	0 255 / 100% / 360° / 63; <u>1</u>
Output value object B if logic = 1	0 255 / 100% / 360° / 63; <u>1</u>
Output value object A if logic = 0	0 255 / 100% / 360° / 63; <u>0</u>
Output value object B if logic = 0	0 255 / 100% / 360° / 63; <u>0</u>
Output value object A If block active	0 255 / 100% / 360° / 63; <u>0</u>
Output value object B If block active	0 255 / 100% / 360° / 63; <u>0</u>
Output value object A if monitoring time exceeded	0 255 / 100% / 360° / 63; <u>0</u>
Output value object B if monitoring time exceeded	0 255 / 100% / 360° / 63; <u>0</u>

Set the output send pattern.

Transmission behaviour	 on change of logic on change of logic to 1 on change of logic to 0 on change of logic and periodically on change of logic to 1 and periodically on change of logic to 0 and periodically on change of logic + object receipt on change of logic + object receipt and cyclically
Send cycle (if sent periodically)	$5 \text{ s} \bullet \underline{10 \text{ s}} \bullet \dots \bullet 2 \text{ h}$

Block

If necessary, activate the block for the logic output and set what a 1 or 0 at the block input means and what happens in the event of a block.

Use block	No • Yes
Assessment of the block object	At value 1: block At value 0: release At value 0: block At value 1: release
Blocking object value before first Commu- nication	<u>0</u> •1
Output behaviour when blocking	Do not send message Send block value [see above, output value if block active]
when released (with 2 second release delay)	[send value for current logic status]

Monitoring

If necessary, activate the input monitoring. Set which inputs are to be monitored, at which intervals the inputs are to be monitored and what value the "monitoring status" should have, if the monitoring period is exceeded without a feedback being given.

Use input monitoring	<u>No</u> •Yes
Input monitoring	•1•2•3•4
	•1+2•1+3•1+4•2+3•2+4•3+4
	• 1 + 2 + 3 • 1 + 2 + 4 • 1 + 3 + 4 • 2 + 3 + 4
	• <u>1 + 2 + 3 + 4</u>
Monitoring period	5 s • • 2 h; <u>1 min</u>
Output behaviour on exceeding the moni-	• Do not send message
toring time	 Send value exceeding [= value of the
	parameter "Monitoring period"]

7.6.2. OR LOGIC connection inputs

The OR logic connection inputs are the same as those for the AND logic. Additionally, the following inputs are available for the OR logic:

Switching output AND logic 1 Switching output AND logic 1 inverted Switching output AND logic 2 Switching output AND logic 2 inverted

Questions about the product?

You can reach the technical service of Elsner Elektronik under Tel. +49 (0) 70 33 / 30 945-250 or service@elsner-elektronik.de

We need the following information to process your service request:

- Type of appliance (model name or item number)
- Description of the problem
- Serial number or software version
- Source of supply (dealer/installer who bought the device from Elsner Elektronik)

For questions about KNX functions:

- Version of the device application
- ETS version used for the project



Elsner Elektronik GmbH Control and Automation Engineering

Sohlengrund 16 75395 Ostelsheim Germany

Phone +49 (0) 70 33 / 30 945-0 info@elsner-elektronik.de Fax +49 (0) 70 33 / 30 945-20 www.elsner-elektronik.de